

PROFORMA REGARDING SAFE DRINKING WATER CERTIFICATE
No..JSV –BSR-SDM-Water Quality/ 1617

Dated:- 18/8/2025


It is certified that and inspection team headed by Er. Ravinder Kumar Assistant Engineer JSV Sub Div Barsar Name of the officer with designation from Jal Shakti Vibhag Sub Division Barsar inspected the premises of Alpine International School Jaure Amb Tehsil Barsar Distt. Hamirpur on 07.8.2025 and found that the school has safe drinking water facility for the student and members of staff of the intuition and it is maintaining the hygienic conditions in the school building & the campus as per the norms prescribed by the state Govt.

The above certificate is valid for one year i.e upto 31-03-2026

Signature with

seal

To
The Principal
Alpine international School Jaure Amb
Distt Hamirpur (HP)


Assistant Engineer
Jal Shakti Vibhag
Sub Division Barsar

HIMACHAL PRADESH JAL SHAKTI VIBHAG
WATER TESTING LABORATORY
PUBLIC HEALTH SUB-DIVISION BHOTA, DISTT. HAMIRPUR

Lab. Ref. No. SHMR.....56..... Dated.....08/08/2025.....
Name & Address of Sender.....Alpine International School..... Division.....
.....Jouse Amb, P.O. Jouse Amb, Teh- Baisah..... Sub Div.....
.....Distt Hamirpur (H.P.)..... Section.....
..... J.E.....

1. Name of Scheme.....This water sample is received from applicant......
2. Nature of Source.....
3. Place of Collection.....
4. Date & Time receipt of laboratory.....08/08/2025.....11:30 AM.....
5. Date and Time of commencing of Examination.....08/08/2025.....12:00 PM.....
6. Nature of Sample:-
1. Raw Water 2. Chlorinated Water 3. Filtered Water
4. Distribution System 5. Hand Pump 6. Well

(A) PHYSICAL TESTS)				
Sr. No.	Parameter	Acceptable	Permissible limit	Result of Sample
1.	Temperature			-
2.	Turbidity (NTU)	1.00 NTU	5.00 NTU	4.2 N.T.U
3.	Colour	5 HU	15 HU	3.0 Hazen Unit
4.	Taste	Agreeable	Agreeable	Agreeable
5.	Odour	Agreeable	Agreeable	Agreeable
6.	PH/Value	6.5-8.5	No relaxation	7.7
7.	TDS / Conductivity	500 mg/l	2000 mg/l	294 mg/l
(B) CHEMICAL TESTS)				
1.	Residual chlorine	0.2 ppm	1.0 ppm	0.0 Ppm
2.	Total Alkalinity	200 mg/l	600 mg/l	284 mg/l
3.	Total hardness mg/ l cacO ₃	200 mg/l	600 mg/l	290 mg/l
4.	Calcium mg/l	75mg/l	200 mg/l	- mg/l
5.	Magnesium (mg)	30 mg/l	100 mg/l	- mg/l
6.	Chloride mg/l	250 mg/l	1000 mg/l	19 mg/l
7.	Iron mg/l	0.3 mg/l	1.0 mg/l	0.0 mg/l
8.	Nitrates mg/l	45 mg/l	No Relaxation	5.0 mg/l
9.	Fluoride mg/l	1.0 mg/l	1.5 mg/l	0.0 mg/l
10.	Sulphate mg/l	200 mg/l	400 mg/l	- mg/l
11.	Arsenic mg/l	0.01 mg/l	0.05 mg/l	0.0 mg/l
(C) BACTERIOLOGICAL TESTS)				
1.	Total No. of coliforms	Nil	Nil	0 MPN/100ml
2.	Feacal Coliforms	Nil	Nil	Nil
1.	E-Coli/100ml	Nil	Nil	Nil

REMARKS:- Above tested parameters are within permissible limit and this
water sample is received from applicant.

Assistant Chemist
JSV Lab. Bhoti

Assistant Engineer
JSV Sub. Div. Bhoti